



Sub Divisional Level Water Quality Testing and Monitoring
Laboratory

Uttarakhand Jal Sansthan, Rishikesh

Ph (O): 0135 – 2430239, E-mail: ujslabrishikesh@gmail.com

Test Report ID: Report No. 08/UJS/SDWQTML/RK/2022-23

Dated: 08/02/2023

WATER QUALITY RETEST REPORT

Name and Address of Organization/ Customer	DSB International Public school , Rishikesh		
Product Description (Surface Water/ Ground Water/ Drinking Water)	Drinking Water	Sample Description	One Water Sample collected from DSB International School Gumaniwala, Rishikesh
Reference Sample Identification:	SDWQTMLRK/UJS/ SCH/08		Date of Start of Analysis: 08/02/2023
			Date of End of Analysis: 13/02/2023
Date and Time of Sample Received: 08/02/2023 & 11:10 AM	Sample Collected by:	Sample Assistant	

SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1.	pH	7.14	6.5 to 8.5	No Relaxation	IS 3025 Pt-11, 2017
2.	Total Dissolved Solids (TDS), mg/L	270	500	2000	IS 3025 Pt-16-2017
3.	Turbidity, NTU	0.56	1	5	IS 3025 Pt-10-2017
4.	Total Alkalinity (as CaCO ₃), mg/L	132	200	600	IS 3025 Pt-23: 2019
5.	Total Hardness (as CaCO ₃), mg/L	168	200	600	IS 3025 Pt-21: 2002
6.	Chloride, mg/l	6	250	1000	IS 3025 Pt-32 : 2019
7.	Calcium (as Ca), mg/L	45	75	200	IS 3025 Pt-40 : 2019
8.	Magnesium (as Mg), mg/L	29.88	30	100	APHA 23rd Ed.-3500-Mg B: 2017
9.	Colour, Hazen	3	5	15	IS 3025 Pt-04 : 2021
10.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 Pt-05 : 2018
11.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 Pt-08 : 2012
12.	Total coliform MPN/100 ml	Absent	Absent	Absent	APHA 23rd Ed-9223-B
13.	E. Coli, MPN/100 ml	Absent	Absent	Absent	APHA 23rd Ed-9223-B

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.

Pinky
अभिषेक कल प्रयोगशाला
उत्तराखण्ड जल संस्थान
रिषिकेश

Pinky
Authorized Signatory
SDWQTML, Rishikesh

—End of Report—

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.




कार्यालय नगर निगम, ऋषिकेश

Haridwar Road Rishikesh, Distt-Dehradun, Pin-249201

☎: www.nagarnigamrshikesh.com, ✉: npprshikesh@gmail.com

☎: 0135-2430015, ①:



PERFORMA REGARDING SANITARY CONDITION CERTIFICATE

NO.....

DATE 01/02/2023

- 1- It is certified that an inspection team headed by Mr. Santosh Singh Gusain (name of officer with designation) from municipal corporation Rishikesh (name of department/office) Inspected the **DSB International public school rishikesh** (Name & address of school) on 01-02-2023 and found that the **DSB International public school rishikesh** (Name of school) is maintaining the hygienic sanitation condition in the school building & campus as per the nomrs prescribed by the central/state/U.T Govt.

The above valid for a period of 01 year.

Signature with seal
Name:- सफाई निरीक्षक
नगर निगम ऋषिकेश

Designation- Sanitary inspector

To Principal
DSB International public school rishikesh
(Name & address of institution)